

# Specifications



## Eaton 276426

Eaton Moeller® series DILA Auxiliary contact module, 4 pole, Ith= 16 A, 2 N/O, 2 NC, Front fixing, Screw terminals, DILA, DILM7 - DILM38

### General specifications

|                     |   |
|---------------------|---|
| <b>PRODUCT NAME</b> | Eaton Moeller® series<br>DILA Accessory Auxiliary<br>contact module |
|---------------------|---|

|                       |        |
|-----------------------|--------|
| <b>CATALOG NUMBER</b> | 276426 |
|-----------------------|--------|

|            |               |
|------------|---------------|
| <b>EAN</b> | 4015082764265 |
|------------|---------------|

|            |              |
|------------|--------------|
| <b>UPC</b> | 782116354597 |
|------------|--------------|

|                             |       |
|-----------------------------|-------|
| <b>PRODUCT LENGTH/DEPTH</b> | 45 mm |
|-----------------------------|-------|

|                       |       |
|-----------------------|-------|
| <b>PRODUCT HEIGHT</b> | 38 mm |
|-----------------------|-------|

|                      |       |
|----------------------|-------|
| <b>PRODUCT WIDTH</b> | 36 mm |
|----------------------|-------|

|                       |          |
|-----------------------|----------|
| <b>PRODUCT WEIGHT</b> | 0.049 kg |
|-----------------------|----------|

|                       |   |
|-----------------------|---|
| <b>CERTIFICATIONS</b> | IEC/EN 60947-4-1<br>CSA-C22.2 No. 14-05<br>UL Category Control No.:<br>NKCR<br>CSA<br>UL 508<br>VDE 0660<br>CSA Class No.: 3211-03<br>CE<br>IEC/EN 60947<br>CSA File No.: 012528<br>UL<br>UL File No.: E29184 |
|-----------------------|---|

|                   |            |
|-------------------|------------|
| <b>MODEL CODE</b> | DILA-XHI22 |
|-------------------|------------|



Powering Business Worldwide

## Features & Functions

|                                 |   |
|---------------------------------|---|
| <b>FEATURES</b>                 | Interlocked opposing contacts within an auxiliary contact module (according to IEC 60947-5-1 Annex L) |
| <b>FUNCTIONS</b>                | For standard applications   |
| <b>FITTED WITH:</b>             | Interlocked opposing contacts<br>Switching elements according to EN 50005                             |
| <b>NUMBER OF POLES</b>          | Four-pole   |
| <b>ELECTRIC CONNECTION TYPE</b> | Screw connection  |

## General information

|   |  |
|---|--|
| <b>CONNECTION</b>                             | Screw terminals  |
| <b>DEGREE OF PROTECTION</b>                   | IP20   |
| <b>SHOCK RESISTANCE</b>                       | 5 g, N/C auxiliary contact, Basic unit with auxiliary contact module, Mechanical, according to IEC/EN 60068-2-27, Half-sinusoidal shock 10 ms<br>7 g, N/O auxiliary contact, Basic unit with auxiliary contact module, Mechanical, according to IEC/EN 60068-2-27, Half-sinusoidal shock 10 ms |
| <b>LIFESPAN, ELECTRICAL</b>                   | 1,300,000 Operations (at 230 V, AC-15, 3 A)  |
| <b>LIFESPAN, MECHANICAL</b>                   | 10,000,000 Operations (DC operated)<br>10,000,000 Operations (AC operated)   |
| <b>MODEL</b>                                  | Top mounting   |
| <b>MOUNTING METHOD</b>                        | Front fastening  |
| <b>OPERATING FREQUENCY</b>                    | 9000 Operations/h  |
| <b>OVERVOLTAGE CATEGORY</b>                   | III  |
| <b>POLLUTION DEGREE</b>                       | 3  |
| <b>PROTECTION</b>                             | Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)   |
| <b>RATED IMPULSE WITHSTAND VOLTAGE (UIMP)</b> | 6000 V AC  |
| <b>TYPE</b>                                   | Front mounting auxiliary contact   |

## Climatic environmental conditions

|  |        |
|--|--------|
| <b>AMBIENT OPERATING TEMPERATURE - MIN</b> | -25 °C |
|--|--------|

|  |       |
|--|-------|
| <b>AMBIENT OPERATING TEMPERATURE - MAX</b> | 60 °C |
|--|-------|

|   |        |
|---|--------|
| <b>AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN</b> | -25 °C |
|---|--------|

|   |       |
|---|-------|
| <b>AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX</b> | 40 °C |
|---|-------|

|  |        |
|--|--------|
| <b>AMBIENT STORAGE TEMPERATURE - MIN</b> | -40 °C |
|--|--------|

|  |       |
|--|-------|
| <b>AMBIENT STORAGE TEMPERATURE - MAX</b> | 80 °C |
|--|-------|

|                          |  |
|--------------------------|--|
| <b>CLIMATIC PROOFING</b> | Damp heat, constant, to IEC 60068-2-78<br>Damp heat, cyclic, to IEC 60068-2-30 |
|--------------------------|--|

## Terminal capacities

|  |  |
|--|--|
| <b>TERMINAL CAPACITY (FLEXIBLE WITH FERRULE)</b> | 1 x (0.75 - 2.5) mm <sup>2</sup> , Screw terminals<br>2 x (0.75 - 2.5) mm <sup>2</sup> , Screw terminals |
|--|--|

|                                  |  |
|----------------------------------|--|
| <b>TERMINAL CAPACITY (SOLID)</b> | 2 x (0.75 - 2.5) mm <sup>2</sup> , Screw terminals<br>1 x (0.75 - 2.5) mm <sup>2</sup> , Screw terminals |
|----------------------------------|--|

|   |                          |
|---|--------------------------|
| <b>TERMINAL CAPACITY (SOLID/STRANDED AWG)</b> | 18 - 14, Screw terminals |
|---|--------------------------|

|                   |                      |
|-------------------|----------------------|
| <b>SCREW SIZE</b> | M3.5, Terminal screw |
|-------------------|----------------------|

|                         |   |
|-------------------------|---|
| <b>SCREWDRIVER SIZE</b> | 0.8 x 5.5/1 x 6 mm, Terminal screw, Standard screwdriver<br>2, Terminal screw, Pozidriv screwdriver |
|-------------------------|---|

|                          |                         |
|--------------------------|-------------------------|
| <b>TIGHTENING TORQUE</b> | 1.2 Nm, Screw terminals |
|--------------------------|-------------------------|

## Electrical rating

|                                       |   |
|---------------------------------------|---|
| <b>RATED OPERATIONAL CURRENT (IE)</b> | <p>10 A at 60 V, DC L/R ≤ 15 ms (with 2 contacts in series)</p> <p>6 A at 60 V, DC L/R ≤ 15 ms (with 1 contact in series)</p> <p>1 A at 220 V, DC L/R ≤ 15 ms (with 1 contact in series)</p> <p>0.5 A at 110 V, DC L/R ≤ 50 ms (with 3 contacts in series)</p> <p>1 A at 60 V, DC L/R ≤ 50 ms (with 3 contacts in series)</p> <p>5 A at 220 V, DC L/R ≤ 15 ms (with 3 contacts in series)</p> <p>2.5 A at 24 V, DC L/R ≤ 50 ms (with 3 contacts in series)</p> <p>10 A at 24 V, DC L/R ≤ 15 ms (with 1 contact in series)</p> <p>0.25 A at 220 V, DC L/R ≤ 50 ms (with 3 contacts in series)</p> <p>3 A at 110 V, DC L/R ≤ 15 ms (with 1 contact in series)</p> <p>6 A at 110 V, DC L/R ≤ 15 ms (with 3 contacts in series)</p> |
|---------------------------------------|---|

|   |     |
|---|-----|
| <b>RATED OPERATIONAL CURRENT (IE) AT AC-15, 220 V, 230 V, 240 V</b> | 4 A |
|---|-----|

|   |     |
|---|-----|
| <b>RATED OPERATIONAL CURRENT (IE) AT AC-15, 380 V, 400 V, 415 V</b> | 4 A |
|---|-----|

|   |       |
|---|-------|
| <b>RATED OPERATIONAL CURRENT (IE) AT AC-15, 500 V</b> | 1.5 A |
|---|-------|

|  |       |
|--|-------|
| <b>RATED OPERATIONAL CURRENT (IE) AT DC-13, 24 V</b> | 2.5 A |
|--|-------|

|  |     |
|--|-----|
| <b>RATED OPERATIONAL CURRENT (IE) AT DC-13, 60 V</b> | 1 A |
|--|-----|

|   |       |
|---|-------|
| <b>RATED OPERATIONAL CURRENT (IE) AT DC-13, 110 V</b> | 0.5 A |
|---|-------|

|  |        |
|--|--------|
| <b>RATED OPERATIONAL CURRENT (IE) AT DC-13, 220 V, 230 V</b> | 0.25 A |
|--|--------|

|                                      |       |
|--------------------------------------|-------|
| <b>RATED INSULATION VOLTAGE (UI)</b> | 690 V |
|--------------------------------------|-------|

## Contacts

|  |  |
|--|--|
| <b>CODE NUMBER</b>                                   | <p>62E in combination with DILA(C)-40</p> <p>44 in combination with DILA(C)-22</p> <p>53 in combination with DILA(C)-31</p>  |
| <b>CONTROL CIRCUIT RELIABILITY</b>                   | <p><math>\lambda &lt; 5 \times 10^{-7}</math> (1 failure at 2,000,000 operations for <math>U_e = 24</math> V DC, <math>U_{min} = 17</math> V, <math>I_{min} = 5.4</math> mA)</p> <p><math>\lambda &lt; 5 \times 1/10^7</math> (1 failure at 2,000,000 operations for <math>U_e = 24</math> V DC, <math>U_{min} = 17</math> V, <math>I_{min} = 5.4</math> mA)</p> |
| <b>NUMBER OF CONTACTS (CHANGE-OVER CONTACTS)</b>     | 0  |
| <b>NUMBER OF CONTACTS (NORMALLY CLOSED CONTACTS)</b> | 2  |
| <b>NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS)</b>   | 2  |

|   |   |
|---|---|
| <b>RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX</b>           | 500 V   |
| <b>SHORT-CIRCUIT PROTECTION RATING</b>                      | Max. 10 A gG/gL, Fuse, Without welding, Auxiliary contacts  |
| <b>SHORT-CIRCUIT PROTECTION RATING WITHOUT WELDING</b>      | 10 A gG/gL, 500 V, Max. Fuse, Contacts  |
| <b>SAFE ISOLATION</b>                                       | 400 V AC, Between auxiliary contacts, According to EN 61140<br>400 V AC, Between coil and auxiliary contacts, According to EN 61140 |
| <b>SWITCHING CAPACITY (AUXILIARY CONTACTS, GENERAL USE)</b> | 1 A, 250 V DC, (UL/CSA)<br>10 A, 600 V AC, (UL/CSA)   |
| <b>SWITCHING CAPACITY (AUXILIARY CONTACTS, PILOT DUTY)</b>  | P300, DC operated (UL/CSA)<br>A600, AC operated (UL/CSA)  |

## Design verification

|   |  |
|---|--|
| <b>EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID</b>                               | 0 W  |
| <b>HEAT DISSIPATION CAPACITY PDISS</b>  | 0 W  |
| <b>HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID</b>                                | 0.16 W   |
| <b>RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)</b>                    | 4 A  |
| <b>STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS</b>                               | 0 W  |
| <b>10.2.2 CORROSION RESISTANCE</b>  | Meets the product standard's requirements.                         |
| <b>10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES</b>                         | Meets the product standard's requirements.                         |
| <b>10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT</b>       | Meets the product standard's requirements.                         |
| <b>10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS</b> | Meets the product standard's requirements.                         |
| <b>10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION</b>                                 | Meets the product standard's requirements.                         |
| <b>10.2.5 LIFTING</b>   | Does not apply, since the entire switchgear needs to be evaluated. |
| <b>10.2.6 MECHANICAL IMPACT</b>   | Does not apply, since the entire switchgear needs to be evaluated. |
| <b>10.2.7 INSCRIPTIONS</b>  | Meets the product standard's requirements.                         |
| <b>10.3 DEGREE OF PROTECTION OF ASSEMBLIES</b>  | Does not apply, since the entire switchgear needs to be evaluated. |
| <b>10.4 CLEARANCES AND CREEPAGE DISTANCES</b>   | Meets the product standard's requirements.                         |
| <b>10.5 PROTECTION AGAINST ELECTRIC SHOCK</b>   | Does not apply, since the entire switchgear needs to be evaluated. |
| <b>10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS</b>                           | Does not apply, since the entire switchgear needs to be evaluated. |

## Resources

|                            |  |
|----------------------------|--|
| CATALOGUES                 | <a href="#">Product Range Catalog Switching and protecting motors</a>                  |
|                            | <a href="#">eaton-product-overview-for-machinery-catalogue-ca08103003zen-en-us.pdf</a> |
| DECLARATIONS OF CONFORMITY | <a href="#">eaton-accessory-declaration-of-conformity-uk251276en.pdf</a>               |
|                            | <a href="#">eaton-accessory-declaration-of-conformity-eu250793en.pdf</a>               |
| DRAWINGS                   | <a href="#">eaton-contactors-mounting-dilm-dimensions.eps</a>                          |
|                            | <a href="#">eaton-contactors-module-dilm-dimensions.eps</a>                            |
|                            | <a href="#">eaton-contactors-mounting-dilm-dimensions-002.eps</a>                      |
|                            | <a href="#">eaton-contactors-frame-dilm-dimensions.eps</a>                             |
|                            | <a href="#">eaton-contactors-contact-dilm-accessory-3d-drawing-008.eps</a>             |
| ECAD MODEL                 | <a href="#">ETN.276426.edz</a>   |
| INSTALLATION INSTRUCTIONS  | <a href="#">eaton-contactors-dila-dilm7-15-dilmp20-il03407013z.pdf</a>                 |
| INSTALLATION VIDEOS        | <a href="#">WIN-WIN with push-in technology</a>  |
| MCAD MODEL                 | <a href="#">eaton-contact-blocks-mcad-drawings-dil-a-xhi-4.dwg</a>                     |
|                            | <a href="#">dil_a_xhi_4.stp</a>  |
| WIRING DIAGRAMS            | <a href="#">2100SWI-115</a>  |

|   |  |
|---|--|
| <b>10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS</b>        | Is the panel builder's responsibility.   |
| <b>10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS</b>                 | Is the panel builder's responsibility.   |
| <b>10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH</b>                 | Is the panel builder's responsibility.   |
| <b>10.9.3 IMPULSE WITHSTAND VOLTAGE</b>                         | Is the panel builder's responsibility.   |
| <b>10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL</b> | Is the panel builder's responsibility.   |
| <b>10.10 TEMPERATURE RISE</b>                                   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| <b>10.11 SHORT-CIRCUIT RATING</b>                               | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| <b>10.12 ELECTROMAGNETIC COMPATIBILITY</b>                      | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| <b>10.13 MECHANICAL FUNCTION</b>                                | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

**PROJECT NAME:**

**PROJECT NUMBER:**

**PREPARED BY:**

**DATE:**



**Eaton Corporation plc** Eaton House  
 30 Pembroke Road  
 Dublin 4, Ireland  
 Eaton.com

Follow us on social media to get the latest product and support information.

